

3.19 DOOR CAUTION PLATE - LOCK-OFF


(PART No. 314.205.001)

The Door Caution Plate (lock-off) provides instructions to personnel who may enter an area protected with FM200.

This version of the caution plate is used when it is necessary to instruct personnel to place the system on manual control before entering the protected area.

One plate is to be fixed to all entrance doors into an FM200 protected area.

Four 4mm fixing holes are provided.



Material: Enamelled Aluminium (22SWG)

Part No. 314-205-001 Door Caution Plate - Lock-off


3.18 MANUAL RELEASE CAUTION PLATE

(PART No. 314.205.003)

The Manual Release Caution Plate provides instructions to personnel on the use of manual controls.

One plate is to be fixed adjacent to all positions from where FM200 can be released manually.

Four 4mm fixing holes are provided.



Part No. 314-205-003 Manual Release Caution Plate